
16 June 2019

TEST REPORT

050



SMART COOLING™ PRO10 SYSTEM

Toyota Showroom

Test Participants:

Project name: TOYOTA SHOWROOM Location: Abu dhabi, UAE

Customer: AL FUTTAIM MOTORS Installer: Gerab Energy Systems

Swiss Integrated Energy Technologies: Ali Soufan

Table of Contents

Introduction:	. 3
Main components:	4
Measuring instruments:	5
Testing Summary	7
Testing data:	10
Conclusion: 1	14
Annex:	15

Introduction:

Type of structure: Toyota showroom, UAE.

Cooling units: Air cooled water chiller Carrier 30XA852, 3 nos of Carrier 30XA852 chill-

ers upgraded with *Smart Cooling*™ out of 3 chillers totally.

Cooling capacity (manufacturer's data): 838 Kw.

Energy consumption (manufacturer's data): 234 Kw.

Chiller booster: Smart Cooling™ PRO 10, adiabatic technology with condenser protec-

tion.

3-unit chiller retrofits were made to reduce the energy consumption of chillers and to increase chiller COP efficiency. Chillers were equipped with intelligent adiabatic pre-cooling system *Smart Cooling* ™ *PRO 10*.

The intelligent adiabatic *Smart Cooling* ™ system combines an **adiabatic evaporative pre-cooling process** and **condenser protection with mechanical air filtration**. The intelligent adiabatic *Smart Cooling* ™ system is mounted externally in front of the **condensers** of the cooling equipment. *Smart Cooling* ™ initiates the **adiabatic process** even before the **mechanical cooling** kicks in and the equipment receives a **temperature-reducing fine mist of processed water** that within the cooling circuit.

Smart Cooling™ ensures 100% condenser protection from direct contact with water.



Main components:

Smart Cooling ™ comprises the following key components: protective membranes, water treatment and recirculation systems, high-pressure water pump, control unit, high-pressure nozzle panels, fasteners, and fixings.

- Protective membranes cover the condenser surface, preventing direct water contact.
- Water system purifies and sterilizes water to prevent mineral buildup and bacteria.
- **Pump** provides 70 bar pressure.
- Control unit regulates operation via real-time data (temperature, humidity, chiller parameters).
- Nozzles spray 5-40 µm droplets.
- A set of fasteners and fixings ensure the compatibility of the equipment with the chiller.



Measuring instruments:

Measurements used a **RIELS RIF 600 W** ultrasonic flow meter. It measures flow based on **ultrasound time difference** across the pipe. Connected to chiller pipes to verify efficiency with $Smart\ Cooling^{TM}$ ON and OFF Energy data was taken from the **electrical substation**.

• Formula:

COP = Cooling (kW) ÷ Electrical (kW)





- Test time: 12 October 2019 27 October 2019
- **Chiller model:** Carrier 30XA602 3 Nos equipped with intelligent adiabatic pre-cooling *Smart Cooling* ™ device



Ambient temperature (in Celsius) and air relative humidity:

- comparison between air temperature and relative humidity before and past $Smart\ Cooling^{\mathsf{TM}}$ condenser coil protective membrane;
- before air inflow into condenser coil.



Ambient air temperature 44°C



Relative air humidity RH 28



Air temperature behind Smart Cooling™ condenser coil protective membrane 29 °C



Relative air humidity behind Smart Cooling™ condenser coil protective membrane RH 75



Testing summary:

The **temperature drop** achieved and measured was of **15°C**. The **average temperature drop** in 14 hours was of 10 to **14 °C**. We see in the data sheet issued by chiller manufacturer "Carrier" the chiller performance in different ambient conditions and with 100% chiller load. As proven by the measurement, the *Smart Cooling* $^{\text{TM}}$ system boosts chiller cooling capacity by **10%** and reduces electricity consumption by **24%**.

Cooling capacity Data Sheet

Unit with option 119 (high energy efficiency)

	Air tei	nperat	ture, "C																						
	25					30					35					40					46				
30XA	CAP kW	COM	P UNIT	COOL I/s	COOL kPa	CAP	COM	W L	COOL I/a	COOL kPa	CAP kW	COMP	W	COOL I/s	kPa	CAP kW	COM	P UNIT	COOL I/s	COOL kPa	CAP kW	COM kW	PUNIT	COOL I/s	kPa
252	295	65.	75	14	16	285	72	81	14	15:	274	78	88	13	1/4	263	86	95	13	131	248	:96	105	12	11:
302	.325	72	82	15	16	313	79	89	15	15	300	87	96	14	14	286	95	104	14	13	269	107	116	13	12
352	354	79	89	17	19	341	87	96	16	18	326	96	105	16	16	310	105	114	15	1.5	291	118	126	14	13
402	420	91	103	20	37	407	99	112	19	35	393	109	121	19	33	378	119	131	18	31	359	133	145	17	28
452	483	107	1.19	23	40	468	117	129	22	38	451	129	141	22	35	433	141	153	21	33	411	157	169	20	30
502	545	117	131	26	39	527	128	142	25	37	508	140	154	24	35	488	154	168	23	32	462	172	186	22	29
602	1560	146	163	31	49	638	159	177	30	46	616	174	191	29	43	593	191	208	28	40	562	213	229	27	37
702	726	154	173	35	40	702	168	188	33	37	677	184	203	32	35	651	201	221	31	33	617	225	244	29	30
752	778	180	199	37	41	753	196	215	36	38	726	215	233	35	36	698	235	254	33	33	663	262	281	32	30
802	849	192	212	40	38	821	209	230	39	36	792	229	249	38	34	762	251	271	36	31	723	280	300	34	28
852	899	196	219	43	43	869	214	237	41	40	838	234	257	40	37	805	256	279	38	35	764	286	308	36	32
902	965	221	244	46	-40	933	241	264	44	38	899	263	286	43	35	864	288	311	41	33	820	321	344	39	30
1002	1073	236	265	51	40	1037	268	286	49	37	1000	282	310	48	35	961	300	337	46	33	911	345	373	43	30
1102	1229	266	297	59	46	1189	291	322	.57	43	1147	318	348	55	40	1103	348	378	53	37	1046	388	418	50	34
1202	1336	298	331	64	47	1292	325	358	62	45	1247	355	388	59	42	1199	389:	421	57	39	1138	434	466	54	35
1302	1452	328	362	69	52	1404	359	392	67	49	1354	393	425	65	46	1301	430	463	62	42	1233	481	513	59	38
1352	1550	362	393	7.4	48	1497	395	426	71	45	1442	433	463	69	42	1385	474	504	66	39	1311	530	560	62	35
1402	1575	345	386	75	50	1523	376	417	73	47	1468	411	451	70	44	1411	450	490	67	41	1339	503	542	64	37
1502	1636	360	401	78	52	1581	393	434	75	48	1523	430	470	73	45	1463	471	511	70	42	1387	526	565	66	38
1702	1795	391	438	86	63	1736	427	474	83	59	1675	467	513	80	55	1610	512	557	77	51	1527	572	616	73	46

	Air ter	mperat	ure, "C	9																					
	25					30					35					40					46				
	CAP	COME	UNIT	COOL	COOL	CAP	COMP	UNIT	COOL		CAP	COMP		COOL	COOL	CAP	COM	UNIT	COOL		CAP	COM	PUNIT	COOL	COOL
AXOE	kW	kW	kW	Va.	kPa	kW	kW	kW	1/8	kPa	kW	kW	kW	1/8	kPa	kW	kW	kW	1/6	kPa	kW	kW	kW	Vs.	kPa
252	323	-88	78	15	18	312	75	84	15	17	300	82	91	14	16	287	90	99	14	15	271	100	109	13	13
302	355	76	85	17	19	342	83	93	16	18	328	91	100	16	16	313	100	109	15	15	294	112	121	1.4	13
352	387	84	93	19	22	372	92	101	18	21	356	101	110	17	19	339	110	119	16	17	318	124	133	15	15
402	460	95	107	22	43	446	104	116	21	41	430	113	126	21	38	414	124	136	20	35	393	138	150	19	32
452	527	113	125	25	46	510	124	136	24	44	492	135	147	23	41	472	148	160	23	38	448	165	177	21	34
502	595	123	138	28	46	575	135	149	27	43	554	147	162	26	40	532	162	176	25	37	504	181	194	24	34
602	722	154	171	34	57	699	168	185	33	54	674	183	200	32	50	648	200	217	31	47	614	223	240	29	42
702	793	162	182	38	46	767	177	197	37	43	740	193	213	35	41	711	211	231	34	38	673	236	255	32	34
752	851	190	209	41	47	823	207	226	39	44	793	226	245	38	41	762	247	266	36	39	723	275	293	35	35
802	929	202	223	44	44	898	220	241	43	42	865	241	261	41	39	832	263	283	40	36	789	293	313	38	33
852	961	207	230	47	49	948	225	249	45	46	914	246	269	44	43	878	269	292	42	40	832	300	323	40	36
902	1055	23.3	257	50	46	1019	254	277	49	43	981	277	300	47	4.1	942	303	326	45	38	893	337	360	43	34
1002	1173	250	279	56	46	1133	272	301	54	43	1091	297	326	52	40	1048	325	353	50	38	993	363	390	47	34
1102	1341	281	312	64	53	1297	307	337	62	50	1251	335	365	60	46	1202	365	396	57	43	1140	407	437	54	39
1202	1458	315	348	70	55	1410	343	376	67	52	1359	374	407	65	48	1306	409	441	62	45	1239	456	487	59	41
1302	1586	347	381	76	60	1532	379	412	73	56	1476	414	447	70	53	1416	453	486	68	49	1322	494	525	63	43
1352	1691	384	415	81	56	1632	419	450	78	52	1571	458	489	75	49	1506	501	531	72	45	1351	517	547	65	37
1402	1721	365	405	82	58	1663	397	438	79	55	1602	434	474	76	51	1538	474	513		47	1458	528	567	70	43
1502	1786	381	422	85	60	1724		456	82	56	1660	453	494	79	52	1594	496	536	76	48	1509	553	592	72	44
1702	1959	413	460	94	73	1894	100	497	90	69	1826	492	538	87	64	1754	538	584	84	59	1663	600	645	79	54

Legend
LWT Leaving water temperature
CAP kW Cooling capacity
COMP kW Compressor power input


UNIT kW Unit power input (compressors, fans and control circuit)

COOL I/s Evaporator water flow rate
COOL kPa Evaporator pressure drop

Application data:

Standard units, refrigerant: R134a Evaporator temperature rise: 5 K Evaporator Iluid: chilled water Fouling factor: 0.18 x 10° (m² K)AW

Performances in accordance with EN 14511.



—— Smart Cooling™ OFF




Summary of 14-day comparison between *Smart Cooling* ™ switched **OFF** for 7 days and *Smart Cooling* ™ switched **ON** for 7 days

- Average ambient temperature during the period between 12 October 2019 and 19
 October 2019 with Smart Cooling™ switched OFF was 33.9 °C
- Average ambient temperature during the period between 20 October 2019 and 27
 October 2019 with Smart Cooling™ switched ON was 31.60 °C

TOYOTA SHOWROOM

3 meters, 20 Oct 2019 - 27 Oct 2019 - 1 hour, System




Eniscope Analytics

Meter	Total	Average	Max	Min
Chiller 1 – E	17.66 MWh	91.97 kWh	133.70 kWh	46.97 kWh
Chiller 2 – E	8.32 MWh	43.32 kWh	112.78 kWh	141.33 kWh
Chiller 3 – E	15.78 MWh	15.78 kWh	112.54 kWh	41.50 kWh

TOYOTA SHOWROOM

3 meters, 12 Oct 2019 - 18 Oct 2019 - 1 hour, System



Eniscope Analytics

Meter	Total	Average	Max	Min
Chiller 1 – E	16.71 MWh	99.47 kWh	134.47 kWh	71.14 kWh
Chiller 2 – E	15.09 MWh	89.81 kWh	157.24 kWh	65.43 kWh
Chiller 3 – E	15.07 MWh	89.73 kWh	130.55 kWh	52.97 kWh

Testing Data:

date	Sirrestamp	Order 1 electricity occumplion in W. E. Emeri Cooling Off	Order 11 C	Challe 1 2019- 10-20 electricity consumption in Wilman occling	Chiller 12019- 10-20 Smart coding on T.C.	Difference in 16 between smart cooling on and off	Other 2 security consumption in VVE Smart Cooling Off	ONN 2-10	Ostar 2 2019- 10-30 electrosty consumption in W Smart decining	Chair 22019- 10-20 Smart cooling on T.C.	Difference in 1/4 between smart cooling on and off	Cream 3 electroty pathwarpton in Wishan Cooling Off	Cooling Off TC*	Oather 3 2019- 10-20 electricity consumption in	Chiller 32019- 10-20 Shert cooling on T.C.	Difference in % between amart coaling on and
12:10:2019:00:00	1570824000	993391	30	93563	39	0%	94001	30	6950)	31:	.29%	8980	32	82705	3t.	4%
12:10:2019:01:00	15/10827600	99122	30	91290	30	-2%	M210	32	69634	30	-05	82548	32	62162	.90	7%
12.10.2019-02:00	1570831200	39014	.32	00738	30	2%	94221	12	68362	30	-27%	62924	32	31442	30	-1%
12.10.2019-03:00	1570034000	90071	32	87207	29	-6%	90670	32	67734	29	-01%	85216	32	90500	29	-0%
12 10 2019 04 00	1570038400	91294	32	00145	29	-5%	95634	32	67054	29	-30%	82967	32	78573	29	-5%
12.10.2019/05:00	1570842000	JH610	32	815-0	20	7%	00755	30	66883	26	-21%	81167	32	71005	28	-5%
12:10:2019-06:00	1570845600	89636	31	92914	20	-3%	D4602	31	66630	28.	-30%	60621	31	77062	28	-5%
12 10 2019 07 00	1570846300	8/730	30	83925	29	-6%	98174	10	FETHOR:	29	-28%	8168	32	77928	29	-5%
12.10.2019-08:00	15/0852800	94530	34	1986	29.	-1%	97675	34	67787	29	-31%	83124	.34	78405	29	-6%
12.10.2019-09:00	1570856400	39717	36	102791	32	3%	100574	ж	71047	12	-9/9.	97676	36	30000	32	-5%
12.10.2019 10:00	1570000000	39005	37	105841	36	8%	111002	- 57	73335	36	-34%	90051	37	110230	36	12%
12:10:2019 11:00	1570863600	123063	40	112908	277	-8%	125064	40.	757-0	17	-10%	100136	40	110000	307	10%
12 10 2019 12:00	1570RE7200	135052	41	113000	39	-9%	130951	41	79674	39	41%	102701	41	109014	39	6%
12:10:2019:13:00	15708/9800	107774	41	116157	40	-0%	137144	41	7901	40	42%	106155	41	112542	40	4%
12.10.2019 14:00	1570874400	121964	42	115211	.39	-6%	140005	40	/5634	39	469	104271	42	J0050	39	-976
12.10.2019 15:00	1570878000	99241	41	103294	37	4%	157344	41	P0420	37	-00%	101048	41	91200	37	-10%
12:10:2019:10:00	1570001000	120446	39	95257	36	-21%	113065	39	00190	36	41%	111547	39	95553	30	-23%
12 10 2019 17:00	1570886200	114635	37	94730	34	-57%	100645	37	64824	38	37%	105727	37	32561	34	22%
12.10.2010 18:00	1570888000	110116	36	90560	33	-10%	100916	36	63603	23	-57%	98304	36	80417	33	-10%
12:10:2019:19:00	1570890400	110071	36	90009	32	-19%	SHACE	95	63456	12	-36%	907176	36	4257V	10	-10%
12 10 2019 20 00	15/1080#000	105841	35	88520	32	-16%	W25F	35	63222	32	-85%	66009	36	78,598	- 32	12%
12.10.2019:21.00	1570899600	100173	34	83040	32	-11%	90230	34	62751	32	-12%	84799	34	91030	32	-4%
12:10:2019:22:00	1570900200	95000	- 34	83807	31	-12%	90130	34	01900	31	-31%	64275	34	31679	31	-3%
12.10.2019 23:00	1570906000	30524	34	83056	21	-54%	84748	34	61528	21	-27%	63019	34	76750	21	-0%
Total KA	Ni consumption	2467		2273		- A	2660		1641			2212		2006		
Telt	KWIH Savings			194					906					136		
10	tal savings in %			4%					-36%					-0%		

Comparison of individual chiller electricity kW/h consumption

October 12 vs October 20

date	timestamp	Chilter 1 electricity consumption in W- E Smert Cooling Off	Chiler 1 T C*	Chiler 1 2019- 10-21 electricity consumption in W Smert cooling on	Chiler 12019- 10:20 Smart cooling on T C	Difference in % between smart cooling on and off	Chiler 2 electricity consumption in VF Smart Cooling Off	Chiler 2 - T C*	Chiller 2 2019- 10-21 electricity consumption in W.Smart cooling on	Chiler 2.2019- 10-20 Smart cooling on T C*	Difference in % between smart coding on and off	Chiller 3 electricity consumption in W Smart Cooling Off	Cooling Off T C*	Chiler 3 2019- 10-21 electricity consumption in	Chiler 3 2019- 10-20 Smart cooling on T C*	Difference in % between smart coding on and off
13.10.2019 00:00	1570910400	95582	33	79664	30	-17%	84380	33	60914	30	-28%	82077	33	75292	30	-8%
13.10.2019 01:00	1570914000	91290	33	79617	29	-13%	79931	33	61003	29	-24%	76267	33	71372	29	-6%
13.10.2019 02:00	1570917600	84014	32	75377	29	-10%	76371	32	60725	29	-20%	73597	32	75000	29	2%
13.10.2019 03:00	1570921200	88862	30	76383	29	-14%	74382	30	60160	29	-19%	52973	30	69818	29	32%
13.10.2019 04:00	1570924800	91865	31	70722	28	-14%	73754	31	60019	28	-10%	64070	31	69582	26	9%
13.10.2019 05:00	1570928400	89876	31	78109	28	-13%	70404	31	59736	28	-15%	57579	31	69111	28	20%
13.10.2019.06:00	1570932000	88044	30	74358	27	-15%	67368	30	59548	27	-12%	54543	30	68451	27	25%
13.10.2019 07:00	1570935600	91708	31	77214	28	-16%	65431	31	59924	28	-8%	68205	31	68451	26	0%
13.10.2019 08:00	1570939200	100607	33	80506	30	-20%	89143	33	60443	30	-32%	75743	33	70053	30	-6%
13.10.2019 09:00	1570942800	106470	36	87361	32	-17%	94535	36	61620	32	-35%	91918	36	81737	32	-11%
13.10.2019 10:00	1670946400	118300	38	88944	34	-26%	103016	38	62616	34	-39%	98199	38	86694	34	-13%
13.10.2019 11:00	1570950000	127879	40	93279	36	-27%	66164	40	63458	36	-4%	115735	40	89086	36	-23%
13.10.2019 12:00	1570953600	134474	40	94456	37	-30%	87154	4)	64400	37	-26%	130548	40	97519	37	-25%
13.10.2019 13:00	1570957200	126047	40	101711	37	-19%	137039	40	64871	37	-53%	104376	40	86872	37	-17%
13.10.2019 14:00	1570960800	125542	41	100439	36	-20%	136516	41	54742	36	-60%	103486	41	88379	36	-15%
13.10.2019 15:00	1570964400	118614	42	96812	35	-18%	138714	42	24874	35	-82%	110967	42	87154	35	-21%
13.10.2019 16:00	1570968000	112018	41	106857	33	-6%	136673	41	188	33	-100%	106731	41	102183	33	-4%
13.10.2019 17:00	1570971600	117410	39	106250	32	-0%	133846	39	168	32	-100%	103172	39	97848	32	-5%
13.10.2019 18:00	1570975200	109034	37	99120	31	-9%	129606	37	188	31	-100%	95320	37	97142	31	2%
13.10.2019 19:00	1570978800	103591	36	100628	30	-3%	124476	36	188	30	-100%	95006	36	96576	30	2%
13.10.2019 20:00	1570982400	101759	35	94504	30	-7%	122487	35	141	30	-100%	91918	36	95917	30	4%
13.10.2019.21:00	1570986000	102910	35	99827	29	-3%	116310	35	141	29	-100%	86578	35	59792	29	4%
13.10.2019.22:00	1570989600	93436	34	58791	29	6%	113798	34	188	29	-100%	86840	34	85223	29	-2%
13.10.2019 23:00	1670993200	85858	34	96812	30	13%	106004	34	141	30	-100%	84432	34	84616	30	0%
Total KW	nt consumption	2506		2163			2427		940			2110		2003		
Tota	KW/H Savings			338					1486					10 7		
To	tal savings in 1%			-13%					-61%					5%		

Comparison of individual chiller electricity kW/h consumption

October 13 vs October 21



data	timestamp	Chile 1 exchacty consumption is W. E Smart Cooking Off	Chiller 1 T.C.	Chair 12019-10. 22 electricity consumption in W Great cooling on	Chiler 1 2010-10- 20 Smart cooling on T C*	Ofference in % between small cooling on and off	Chiler 2 exercisty consumption in W E Smart Cooleg Cit	Offer 2-10"	Chile: 2 2019-10- 22 electricity persymptom in W Smart cooling on	Chair 22019-10- 20 Smart coning on T.C.	Ofference in % between small cooling on and off	Chilter 1 electricity Denoumption in W Ernant Cooling Off	Chiler 3 Emart Cooling Off T C*	Order 32019-10- 22 electricity consumption in W	Chiler 3 2019-10- 20 Smart cooling on T.C*	Ofference in the between smart cooling on and off
14 10 2019 00:00	1570996800	80768	33	67934	29		104062	33	141	29		83804	33	87154	29	4%
14 10 2019 01 00	\$579000400	1965.78	32	89019	29		97347	32	141	29		78884	32	84940	29	8%
14.10.2019-02:00	1571004000	78517	31	68096	28		86840	31	141	29		76895	31	83841	28	5%
14.10.2019 03:00	1571007600	86421	31	90311	28		96529	31	188	28		77940	- 31	77544	28	-1%
14 10 2019 04:00	1571011200	86113	-31	85741	23		89510	31	141	2/		61139	- 31	/6366	27	26%
14.10.2019-05:00	167101480C	86270	30	66882	27		91300	30	141	27		69043	30	77120	27	12%
18,10,2019.06:00	1571018400	82192	30	84966	27		96472	30	141	27		69636	33	72409	27	21%
14.10.2019-07:00	1571022000	87887	30	78627	27		88306	30	627E	27		75220	30	78722	27	5%
14.10.2019.08:00	1571025600	97100	32	77355	28		162230	32	76696	28		81187	32	67980	28	16%
14 10 2019 09:00	1571029200	107863	34	76837	30		118038	34	88191	30		84432	34	69158	30	-18%
14.10.2019 10:00	1671032800	106841	36	63433	32		121650	36	96729	32		88463	36	71231	32	-19%
14,10,2019 11:00	1571036400	100816	36	83291	34		122644	36	56638	34		94011	39	73350	34	-22%
14,10,2019 12:00	1571940000	197058	39	64752	36		126068	39	101005	36		95320	39	75659	36	-21%
14.10.2019 12:00	1571043600	111599	40	64752	37		134108	40	103596	37		114426	40	76366	37	-33%
14.10.2019 14.00	1571047200	115662	41	66113	.36		136626	41	85129	36		105784	41	75413	36	-28%
14.10.2019 15:00	1571050800	114521	40	101900	36		136201	40	32450	36		103852	40	102277	35	-2%
14,10,2019 16:00	1571054400	114217	39	63133	35		134212	29	105366	35		96172	39	31330	55	-16%
14.10.2019 17.00	1571056000	99298	37	61295	34		129167	37	104505	34		102073	- 37	73069	34	-28%
14.10.2019 18.00	1571061600	93059	35	77591	33		124162	35	101193	33		96524	35	73210	33	-24%
14.10.2019 19:00	1571065200	95111	34	82113	32		124057	34	30544	32		88568	.34	72580	32	-18%
14:10:2019:20:00	1571068800	92336	.33	61124	32		115159	33	56671	32		85427	33	75942	32	-11%
14 10 2019 21:00	1571072400	86107	33	80417	32		107778	33	53561	22		83909	33	72597	32	-13%
14.10.2019.22:00	1571076000	85375	35	61737	31		102439	32	95163	38		62234	32	74340	31	-10%
14 10 2019 23:00	1571079600	62077	31	77544	31		101611	31	66144	31		80611	31	72456	21	-10%
Total KW/H	consumption	2281		2016			7688		1472			2067		1664		
Total K	With Savings			265					1214					225		
Yotal	savings in %			-12%					46%					-11%		

Comparison of individual chiller electricity kW/h consumption

October 14 vs October 22

date	timestamp	Chiler 1 dectricity consumption in W - E Smart Cooling Orf	Chiler 1TC*	Chiller 1 2019-10. 23 electricity consumplion in W Smart cooling on	Chiler 1 2019-10- 20 Smart cooling on T C*	Difference in % between smart cooling on and off	Chiller 2 electricity consumption in W E Smart Cooling	Chiler 2 - T C*	Chiler 2 2019-10. 23 electricity consumplien in W Smart cooling on	Chiler 2 2019-10- 20 Smart cooling on T C*	Difference in % between smart cooling on and off	Chiller 3 electricity consumption in W Smart Cooling Off	Coding Off T C*	Chiller 32019-10- 23 electricity consumption in W	Chiler 3 2019-10- 20 Smart cooling on T C*	Difference in % between smart cooling on and off
15.10.2019 00:00	1571063200	82443	31	77214	30		94797	31	87201	30		80192	31	70760	30	-12%
15.10.2019 01:00	1571086800	80088	30	77073	29		89510	30	87201	29		75952	30	70147	29	-8%
15.10.2019 02:00	1571090400	78622	29	73822	29		88829	29	85600	29		70195	29	69676	29	-1%
15.10.2019 03:00	1571094000	72288	23	76649	28		81501	23	88944	28		66478	28	69299	28	4%
15.10.2019 04:00	1571097600	71137	28	72362	28		79512	28	85081	28		66687	28	65907	28	-1%
15.10.2019 06:00	1571101200	78360	27	69394	28		78360	27	61291	28		54962	27	61950	28	13%
15.10.2019 06:00	1571104800	77366	27	86165	27		74644	27	188	27		55538	27	81878	27	47%
15.10.2019 07:00	1571108400	74749	28	89039	27		78360	28	188	27		65798	28	83527	27	27%
15.10.2019 08:00	1571112000	82496	30	96435	29		92493	30	166	29		74958	30	89321	29	19%
15.10.2019 09:00	1571115600	92965	31	98367	31		99298	31	188	31		80611	31	95022	31	18%
15.10.2019 10:00	1571119200	79617	35	105245	33		118771	35	188	33		84485	35	106611	33	26%
15.10.2019 11:00	1571122800	99089	37	119943	35		116834	37	188	35		94901	37	103407	35	9%
15.10.2019 12:00	1571126400	108558	33	129559	36		124057	33	188	36		93750	38	102418	36	9%
15.10.2019 13:00	1571130000	105580	43	131862	37		130286	40	188	37		103800	40	105857	37	2%
15.10.2019 14:00	1571133600	113536	40	120102	37		130077	40	100	37		100059	40	110521	37	10%
15.10.2019 15:00	1571137200	108197	40	124507	36		130129	40	236	36		103852	40	112170	36	8%
15.10.2019 16:00	1571140800	114112	33	124419	34		91656	33	188	34		102544	38	110144	34	7%
15.10.2019 17:00	1571144400	113850	37	122440	33		77470	37	188	33		106784	37	100561	33	-6%
15:10:2019 18:00	1571148000	100616	35	115259	32		75377	35	236	32		100345	35	96482	32	-4%
15.10.2019 19:00	1571151600	98304	34	112971	31		74016	34	188	31		98775	34	96058	31	-3%
15.10.2019 20:00	1571155200	100764	33	106375	30		72812	33	166	30		92598	33	92902	30	0%
15.10.2019.21:00	1571158800	98094	33	103313	30		71241	33	236	30		91865	33	100251	30	9%
15.10.2019 22:00	1571162400	94064	32	102654	29		70613	32	188	29		88620	32	92666	29	5%
15.10.2019 20:00	1571166000	92389	31	100523	29		69828	31	186	29		87416	31	90264	29	3%
Total KWII	H consumption	2218		2442			2210		499			2042		2178		
Total	KW/H Savings			-224					1712					-136		
Tot	al savings in %			10%					-77%					7%		

Comparison of individual chiller electricity kW/h consumption

October 15 vs October 23



date	timestamp	Chiller 1 electricity consumption in W-E Smart Cooling Off	Chiler 1 T C*	Chiller 1 2019-10.24 electricity consumption in W Smart cooling on	Chiller 1 2019-10-24 Smart cooling on T	Difference in % between smart cooling on and off	Chiller 2 electricity consumption in W E Smart Cooling Off	Chiller 2 - T C*	Chiller 2 2019-10-24 electricity consumption in W Smart cooling on	Challer 2 2019-10-24 Smart cooling on T	Difference in % between smart cooling on and off	Chiller 3 electricity consumption in VV Smart Cooling Off	Chiller 3 Smart Cooling Off T.C*	Chiller 3 2019-10-24 electricity consumption in W	Chiller 3 2019-10-24 Smart cooling on T	Difference in % between smart cooling on and off
16.10.2019 00:00	1571169600	92022	31	101146	29		69409	31	188	29		84066	31	91300	29	9%
16.10.2019 01:00	1571173200	87730	30	101099	29		68886	30	188	29		83386	30	88238	29	6%
16.10.2019 02:00	1571176800	87154	30	98037	28		68572	30	188	28		81344	30	89368	28	10%
16.10.2019 03:00	1571180400	85689	29	94880	28		67630	29	188	28		78779	29	90640	28	15%
16.10.2019 04:00	1571184000	80192	28	93373	28		67211	28	188	28		77942	28	86118	28	10%
16.10.2019 05:00	1571187500	81553	28	94645	27		66373	28	158	27		77052	28	87154	27	13%
16.10.2019 06:00	1571191200	74068	28	83803	27		66164	28	188	27		76371	28	84281	27	10%
16.10.2019 07:00	1571194000	80402	29	92996	28		66792	29	141	28		76999	29	85647	28	11%
16.10.2019 08:00	1571198400	88358	30	96859	30		68467	30	198	30		79146	30	88992	30	12%
16.10.2019 09:00	1571202000	101340	31	96399	31		70037	31	188	31		86788	31	94504	31	9%
16.10.2019 10:00	1671205600	104796	34	116468	34		72145	34	188	34		86945	34	100676	34	10%
16.10.2019 11:00	1571209200	113903	36	123759	37		74277	36	188	37		104690	36	107082	37	2%
16.10.2019 12:00	1571212800	120603	38	124560	38		77470	38	188	38		108563	38	101146	38	-7%
16.10.2019 13:00	1571216400	126936	40	133464	38		79721	40	236	38		120027	-40	101900	38	-15%
16.10.2019 14:00	1571220000	115735	40	131155	39		80140	40	188	39		120655	40	104350	39	-14%
16.10.2019 15:00	1571223500	120603	39	133699	38		79198	39	188	38		115368	39	104161	38	-10%
16.10.2019 16:00	1571227200	122435	37	125220	36		77869	37	236	36		106993	37	101564	36	-5%
16.10.2019 17:00	1571230000	120603	37	120038	34		77052	37	108	34		104699	37	107506	34	2%
16.10.2019 18:00	1571234400	108302	36	113066	32		76167	36	236	32		96042	36	107223	32	9%
16.10.2019 19:00	1571238000	106004	34	108542	31		73869	34	188	31		94326	34	112170	31	19%
16.10.2019 20:00	1571241500	102177	33	110992	30		72184	33	236	30		90975	33	109343	30	20%
16.10.2019 21:00	1571245200	101916	33	105969	30		71241	33	188	30		92860	33	98655	30	6%
16.10.2019 22:00	1571248800	97414	32	99874	30		70613	32	188	30		92336	32	102795	30	11%
16.10.2019 23:00	1571252400	94221	31	107270	29		70352	31	188	29		97205	31	95210	29	-2%
Total KW/H	consumption	2413		2611			1731		5			2236		2340		
Total	KW91 Savings			-198					1726					-104		
Tota	l savings in %			8%					-100%					5%		

Comparison of individual chiller electricity kW/h consumption

October 16 vs October 24

date	timestamp	Chiller 1 electricity consumption in W- E Smart Cooling	O'siler 1 T C*	Chiller 1 2019-10- 25 electricity consumption in W Smart cooling on	Chiller 1 2019-10- 25 Smart cooling on TC*	Difference in % between smart cooling on and off	Chilter 2 electricity consumption in W E Smart Cooling Off	Chiler 2 - T C*	Chiler 2 2010-10- 25 efecticity consumption in W Smart cooling on	Chiler 2 2019-10- 25 Smart cooling on T.C*	Difference in % between smart cooling on and off	Chilter 3 electricity consumption in W Smart Cooling Off	Chiler 3 Smart Cooling Off T C*	Critier 32019-10- 25 electricity consumption in W	Chiler 3 2019-10- 25 Smart cooling on T.C*	Difference in 16 between smart cooling on and off
17.10.2019 00:00	1571256000	96786	31	100015	26		70142	31	188	28		86631	31	94080	28	9%
17.10.2019 01:00	1571259600	94064	31	99403	26		69462	31	183	28		81396	31	89640	28	10%
17.10.2019 02:00	1571263200	90661	31	102041	26		69305	31	183	23		93122	31	87861	28	-6%
17.10.2019 03:00	1571266800	86474	29	98649	28		68205	29	183	28		79983	29	87672	28	10%
17.10.2019 04:00	1571270400	81658	28	96812	26		65344	28	183	28		77155	28	86118	28	12%
17.10.2019 05:00	1571274000	81239	28	89867	27		66583	28	183	27		76733	28	86636	27	13%
17.10.2019 06:00	1571277600	75900	28	89039	27		66583	28	183	27		71398	28	85458	27	20%
17.10.2019 07:00	1571281200	76256	29	92364	26		67316	29	183	23		78151	29	82302	28	5%
17.10.2019 08:00	1571284800	93540	31	91960	30		69619	31	183	30		80873	31	84563	30	5%
17.10.2019 09:00	1571288400	97623	33	103078	31		71960	33	183	31		89875	33	83857	32	-7%
17.10.2019 10:00	1571292000	103381	34	68623	33		73492	34	141	33		86893	34	73681	53	-15%
17.10.2019 11:00	1571295600	105296	37	119613	36		76110	37	183	36		99455	37	97707	36	-2%
17.10.2019 12:00	1571299200	120341	39	120791	38		78988	39	183	33		105684	39	99686	38	-6%
17.10.2019 13:00	1571302800	123534	40	118436	38		81187	40	183	38		115106	43	102935	38	-11%
17.10.2019 14:00	1571306400	131176	41	123900	36		83281	41	235	33		110134	41	99073	38	-10%
17.10.2019 15:00	1571310000	125418	41	122063	36		83071	41	188	38		114583	41	97471	38	-15%
17.10.2019 16:00	1571313600	119556	40	117776	36		81967	40	183	36		111390	40	93561	36	-16%
17.10.2019 17:00	1571017200	80542	38	110757	35		79090	36	183	35		114164	33	90550	35	-21%
17.10.2019 18:00	1571320800	94326	36	104726	32		76842	36	236	32		97047	36	84281	32	-13%
17.10.2019 19:00	1571324400	96053	34	93467	31		74544	34	183	31		92912	34	32208	31	-12%
17.10.2019 20:00	1571328000	100921	34	93137	30		73754	34	188	30		91499	34	84657	30	-7%
17.10.2019 21:00	1571331600	96979	33	90640	29		72759	33	183	29		50133	33	36495	29	-4%
17.10.2019 22:00	1571336200	102701	33	91206	29		72027	33	183	29		89876	33	89227	29	-1%
17.10.2019 23:00	1571338800	96351	32	91771	29		70980	32	183	29		87835	32	83574	29	-5%
Total KWH	consumption	2302		2430			1764		5			2222		2134		
Total	KW.H Savings			-49					1759					89		
Tota	d savings in %			2%					-100%					-4%		

Comparison of individual chiller electricity kW/h consumption

October 17 vs October 25




date	timestamp	Chiller 1 electricity constumption in W- E Smart Cooling	Onler 1 T C*	Chiller 1 2019-10- 25 electricity consumplion in W Smart cooling on	Chiller 1 2019-10- 25 Smart cooling on T.C*	Difference in % between smart cooling on and off	Chiler 2 electricty consumption in W E Smart Cooling Off	Chiler 2 - T C*	Chiler 2 2019-10- 25 electricity consumption in W Smart cooling on	Chiler 2 2019-10- 25 Smat cooling on T.C*	Difference in 16. Detween smart cooling on and off	Chiler 3 electricity consumption in W Smart Cooling Off	Chiler 3 Smart Cooling Off T C*	Criter 32019-10- 25 electricity consumption in W	Chiler 3 2019-10- 25 Smat cooling on TC*	Difference in % between smart cooling on and off
17.10.2019 00:00	1571256000	96786	31	100015	26		70142	31	183	28		86631	31	94080	28	9%
17.10.2019 01:00	1571259600	94064	31	99403	26		69462	31	188	28		81395	31	89840	28	10%
17.10.2019 02:00	1571263200	90661	31	102041	26		69305	31	183	28		93122	31	87961	28	-6%
17.10.2019 03:00	1571266800	86474	29	98649	28		68205	29	183	28		79983	29	87672	28	10%
17.10.2019 04:00	1571270400	81658	28	96612	26		65344	28	183	28		77155	28	86118	28	12%
17.10.2019 05:00	1571274000	81239	28	89867	27		66583	28	183	27		76733	28	86636	27	10%
17.10.2019 06:00	1571277600	75900	28	89039	27		66583	28	188	27		71393	28	85458	27	20%
17.10.2019 07:00	1571281200	76256	29	92364	26		67316	29	183	28		78151	29	32302	28	5%
17.10.2019 08:00	1571284800	93540	31	91960	30		69619	31	188	30		80873	31	84563	30	5%
17.10.2019 09:00	1571288400	97623	33	103078	31		71990	33	188	31		89875	33	83857	32	-7%
17.10.2019 10:00	1571292000	103381	34	68623	33		73492	34	141	33		86893	34	73681	53	-15%
17.10.2019 11:00	1571295600	105296	37	119613	36		76110	37	188	36		99455	37	97707	36	-2%
17.10.2019 12:00	1571299200	120341	39	120791	38		78988	39	183	38		105684	39	99686	38	-6%
17.10.2019 13:00	1571302800	123534	40	118436	38		81187	40	188	38		115106	43	102935	38	-11%
17.10.2019 14:00	1571306400	131176	41	123900	36		83281	41	235	33		110134	41	99073	38	-10%
17.10.2019 15:00	1571310000	125418	41	122063	36		83071	41	188	38		114583	41	97471	38	-15%
17.10.2019 16:00	1571313600	119556	40	117776	36		81967	40	183	36		111390	40	93561	36	-16%
17.10.2019 17:00	1571317200	83542	38	110757	35		79093	36	183	35		114164	33	90593	35	-21%
17.10.2019 18:00	1571320800	94326	36	104726	32		76842	36	236	32		97047	36	84281	32	-13%
17.10.2019 19:00	1571324400	96053	34	93467	31		74544	34	183	31		92912	34	32208	31	-12%
17.10.2019 20:00	1571328000	100921	34	99137	30		73754	34	188	30		91499	34	84657	30	-7%
17.10.2019 21:00	1571331600	99979	33	90640	29		72759	33	183	29		50133	33	36495	29	-4%
17.10.2019 22:00	1571336200	102701	33	91206	29		72027	33	183	29		89876	33	89227	29	-1%
17.10.2019 23:00	1571338800	96351	32	91771	29		70980	32	183	29		87835	32	83574	29	-5%
Total KWH	consumption	2302		2430			1764		5			2222		2134		
Total	KW.H Savings			-49					1759					89		
Total	savings in %			2%					-100%					-4%		

Comparison of individual chiller electricity kW/h consumption

October 18 vs October 26

Total chiller electricity consumption comparison for 7 days - in kw/h



Conclusion:

- Average ambient temperature during the period between 12/10/2019 19/10/2019
 with Smart Cooling™ switched OFF was 33.9 degrees Celsius
- Average ambient temperature during the period between 20 October 2019 27
 October 2019 with Smart Cooling™ switched ON was 31.60 degrees Celsius
- Total 7-day consumption of three chillers with Smart Cooling™ OFF (kW/h): 46 873 kW/h
- 2. Total 7-day consumption of three chillers with *Smart Cooling* ™ ON (kW/h): **36 293 KW/h**
- 3. Total savings in kW/h: 10 580 KW/h

1. rabille

- 4. Savings in percentage: 22.57%
- 5. 7-day usage of water: 50 m3

The estimated savings based on a **10°C** temperature decrease and 100% of chiller load was of **543 Kw/h** per chiller within 24 hours with *Smart Cooling* ™ operating for 14 hours.

Based on site measurements we can see that without $Smart\ Cooling^{\mathsf{TM}}$ all three chillers operate with an average load of 50%, while with $Smart\ Cooling^{\mathsf{TM}}$ in operation the third chiller goes into standby mode due to sufficient cooling capacity. The operating chillers remain at load levels of 50-60%.

With 50%-60% chiller load, $Smart\ Cooling^{\mathsf{TM}}$ was able to deliver an average of **503 Kw/h** savings per chiller within 24 hours, significantly more than expected. Such results are achieved due to $Smart\ Cooling^{\mathsf{TM}}$ decrease of, on average, **15°C** and increased operating time.

Ali Soufan

30 October 2019



Annex:



Riels instruments srl Viale Spagna, 16 35020 Ponte San Nicolò (PD) - ITALY Ph. +39 0498961771 | info@riels.it

Date

Model:



15/12/2018

RIF600W



RIF600 | Clamp-on Ultrasonic Meter Calibration Report

Pipe diameter DN80
Ambient temperature 29°C
Standard Device before test Normal
Standard Devide After Test Normal
Test result Qualified
Measured Medium Water

Measured Medium Water
Accuracy 1%
Signal Strength UP:

Signal Strength UP: 90 DOWN: 90

Standard device name Static volumetric method/standard Meter Method Water Flow/Standard Device

Standard device accuracy 0,20%

Test	Standard Meter flow		Temperature	Pressure	Tested Meter Flow		Basic Error		Repeatability	
Point	m3/h		°C	Mpa	m3/h		%		%	
	101,52		25,0	0,300	102,27		0,739		\top	
Point 1	101,47	101,47	25,0	0,300	102,07	102,10	0,591]	-0,147	
	101,42	1	25,0	0,300	101,97	1	0,542			0,147
Point 2	71,27	71,27	25,0	0,300	71,75	71,75	0,673	0,759	-0,146	
	71,19		25,0	0,300	71,65		0,646			
	71,34		25,0	0,300	71,86		0,729			
Point 3	26,32	26,36	25,0	0,300	26,51	26,55	0,722		-0,132	
	26,36		25,0	0,300	26,56		0,759			
	26,39		25,0	0,300	26,58		0,720			

Verification Based on

JJG 1030-2007 < Ultrasonic flowmeter verification procedures >

Scale Factor=1

Riels instruments srl | test Report

Pag. 1 di 2





Riels instruments srl Viale Spagna, 16 35020 Ponte San Nicolò (PD) - ITALY Ph. +39 0498961771 | info@riels.it



RIF600W

Model:



RIF600 |Test Report misuratore di portata ad ultrasuoni clamp on

Diametro tubazione DN80 Date 15/12/2018
Temperatura ambiente 29°C

Dispositivo standard prima del test Normale Dispositivo standard dop il test Normale

Dispositive standard dop it test
Risultate del test
Liquido Acqua
Accuratezza 1%
Potenza dei segnali UP: S
DOWN: S

Tipo di dispositivo standard Metodo volumetrico statico/Misuratore di portata volumetrico

Accuratezza del dispositivo standa 0,20%

Test	Misuratore standard		Temperatura	Pressione	Misuratore testato		errore base		Ripetibilità	
Punti	m3/h		°C	Mpa	m3/h		%		%	
	101,52		25,0	0,300	102,27		0,739			
Punto 1	101,47	101,47	25,0	0,300	102,07	102,10	0,591		-0,147	
	101,42		25,0	0,300	101,97		0,542			
	71,27		25,0	0,300	71,75		0,673	1 1		1
Punto 2	71,19	71,27	25,0	0,300	71,65	71,75	0,646	0,759	-0,146	0,147
	71,34		25,0	0,300	71,86		0,729			1
Punto 3	26,32	26,36	25,0	0,300	26,51	26,55	0,722		-0,132	
	26,36		25,0	0,300	26,56		0,759			
	26,39		25,0	0,300	26,58		0,720			

Verification Based on

Scale Factor=1

JJG 1030-2007 < Ultrasonic flowmeter verification procedures >

Riels instruments srl | test Report

Pag. 2 di 2

