

**SMART COOLING™ PRO10 SYSTEM**

# Double Tree by Hilton

Test Participants:

Project name: **DUBAI AL BARSHA HOTEL** Location: Dubai, UAE

Carrier UTS Engineer: **Iftikhar Amin**

Hilton al Barsha Hotel Engineer: **Jethi Thoma**

Gerab Energy Systems Engineer: **Ali Soufan**

Swiss Integrated Energy Technologies: **Luca Gallarate**

## Table of Contents

<b>Introduction:</b> .....	<b>3</b>
<b>Main components:</b> .....	<b>4</b>
<b>Measuring instruments:</b> .....	<b>5</b>
<b>5-day testing measurement outcomes</b> .....	<b>7</b>
<b>Test Nr.1:</b> .....	<b>8</b>
<b>Five-day electricity consumption comparison:</b> .....	<b>8</b>
<b>Test Nr.2:</b> .....	<b>13</b>
<b>30-day overview chart:</b> .....	<b>14</b>
<b>ROI summary</b> .....	<b>15</b>
<b>Annex</b> .....	<b>16</b>

## Introduction:

**Type of structure:** Multistory hotel building.

**Cooling units:** Air cooled water chiller **Carrier 30XA 1002** (2 units).

**Cooling capacity per manufacturer:** 1000 kW

**Electricity consumption per manufacturer:** 344 kW

**Chiller booster:** *Smart Cooling™ PRO 10*, adiabatic technology with condenser protection.

Chillers were retrofitted with the intelligent adiabatic *Smart Cooling™* system to reduce electricity consumption and increase COP.

System description (full original text preserved):


- Combines adiabatic evaporative **pre-cooling + condenser protection + mechanical air filtration**
- **Mounted externally** in front of condensers
- **Initiates adiabatic cooling** before mechanical cooling
- Applies fine mist of processed water **to reduce condensation temperature.**

**Smart Cooling™ ensures 100% condenser protection from direct contact with water.**

## Main components:

*Smart Cooling™* comprises the following key components: protective membranes, water treatment and recirculation systems, high-pressure water pump, control unit, high-pressure nozzle panels, fasteners, and fixings.

- **Protective membranes** cover the condenser surface, preventing direct water contact.
- **Water system** purifies and sterilizes water to prevent mineral buildup and bacteria.
- **Pump** provides 70 bar pressure.
- **Control unit** regulates operation via real-time data (temperature, humidity, chiller parameters).
- **Nozzles** spray 5–40 µm droplets.
- A set of **fasteners and fixings** ensure the compatibility of the equipment with the chiller.



## Measuring instruments:

- RIF600 ultrasonic waterflow meter
- Eniscope Analytics energy monitoring
- COP formula:  $EI/\text{kw} \div \text{cooling}/\text{kw} = \text{COP}$



Chiller with Smart Cooling™ system



Chiller without Smart Cooling™ system

- **Equipment tested:** Air-cooled water chillers, **CARRIER 30XA1002**.


Picture No.2

Chiller equipped with chiller  
equipped with **Smart Cooling™**



## Testing procedures

A data logger was installed on the subject HVAC equipment to collect all applicable real-time electricity consumption and unit performance statistics. Data was collected by the Eniscope Analytics device.



*Temperature probe Nr.1  
Probe showing inflowing air temperature past the protective membrane: +28.6° Celsius.*



*Temperature probe Nr.2  
Probe showing inflowing air temperature before reaching the protective membrane: +43.0° Celsius.*

During the first 5 days (120 hours of use) of testing measured electricity consumption by the condenser without *Smart Cooling*™. During this period the chillers consumed **70,112 KW/h**. Water consumption was **0 m³** and the average temperature and relative humidity during the period were **36°C** and **34% RH**.

During the following 5 days (120 hours of use), with *Smart Cooling*™ switched on and fully operational, data gathered shows the chiller consumed **53,386 KW/h**. Water consumption was **88 m³** and the average temperature and relative humidity during the period were **36°C** and **45% RH**.

After analyzing the monitoring, results show that energy savings gain delivered by *Smart Cooling*™ during 5 operating days was **16,726 KW/h**.


In the following pages, tables discriminate electricity consumption, air temperature and operating periods, before and after *Smart Cooling*™.

## 5-day Periods On-Off Testing Measurement Outcomes

With *Smart Cooling*™, in a period of 5 days, the customer economized **16,726 kw/h** of electricity. Electricity supply charges were, at the time, **0.46 Emirati Dirham (AED)** per kw/h. Thus, total savings in electricity charges were of **7,693 AED**.

Water usage during the period was **88 m³** and water supply charges at the time were **10.5 AED** per m³.

In total, water supply expenses were of **924 AED**.



*Smart Cooling*™ granted total savings post running costs of **6,769 AED** in 5 days or **1,353 AED** per day. On average, *Smart Cooling*™ reduced electricity consumption by **3,345 kw/h** per day.

*Smart Cooling*™ engineers forecasted **17%** savings for a 14-hour period within a 24-hour operational period – initially evaluated as **755 kw/h** savings based on a **10°C** temperature drop.

However, the results measured during the system's operation show that *Smart Cooling*'s™ performance went well beyond predictions, delivering on average a **14°C** decrease and further boosting chiller efficiency.

## Test 1

Five-day electricity consumption comparison – 17 to 21 June with *Smart Cooling™ OFF* and 3 to 7 June with *Smart Cooling™ ON*

Date	Total chiller consumption in kWh with Smart Cooling™ OFF 17 June	Total chiller consumption in kWh with Smart Cooling™ ON 3 June	Savings in kWh	Savings in %	Chiller load with Smart Cooling™ OFF	Chiller load with Smart Cooling™ ON	Temperature with Smart Cooling™ OFF 17 June	Temperature with Smart Cooling™ ON 3 June
17/06/2019 00:00	525	292	233	45%	84%	57%	33.49	31.00
17/06/2019 01:00	504	347	157	31%			33.34	30.44
17/06/2019 02:00	496	302	193	39%			32.79	30.01
17/06/2019 03:00	480	304	176	37%			32.59	29.87
17/06/2019 04:00	480	368	112	23%			32.51	30.02
17/06/2019 05:00	468	302	166	35%			32.26	29.87
17/06/2019 06:00	443	304	139	31%			31.21	29.79
17/06/2019 07:00	412	338	78	18%			32.13	30.99
17/06/2019 08:00	469	365	104	22%			34.63	34.04
17/06/2019 09:00	497	391	105	21%			36.81	34.78
17/06/2019 10:00	469	394	104	21%			38.01	35.98
17/06/2019 11:00	519	397	122	24%			41.79	38.24
17/06/2019 12:00	572	379	193	34%			42.82	38.82
17/06/2019 13:00	581	400	182	31%			39.74	36.75
17/06/2019 14:00	569	427	142	25%			38.05	36.26
17/06/2019 15:00	564	506	59	10%			37.39	35.12
17/06/2019 16:00	565	470	95	17%			38.11	34.58
17/06/2019 17:00	566	493	102	17%			35.42	34.00
17/06/2019 18:00	606	483	123	20%			34.10	33.02
17/06/2019 19:00	565	454	111	20%			33.54	32.48
17/06/2019 20:00	543	440	103	19%			33.17	32.38
17/06/2019 21:00	568	413	155	27%			32.79	32.29
17/06/2019 22:00	466	451	45	9%			32.25	32.17
17/06/2019 23:00	487	391	78	18%			32.06	32.38
Day Total	12463	9408	3075	25%				

Date	Total chiller consumption in kWh with Smart Cooling™ OFF		Total chiller consumption in kWh with Smart Cooling™ ON		Savings in kWh	Savings in %	Chiller load with Smart Cooling™ OFF	Chiller load with Smart Cooling™ ON	Temperature with Smart Cooling™ OFF		Temperature with Smart Cooling™ ON	
	18 June	4 June	18 June	4 June					18 June	4 June	18 June	4 June
18/06/2019									32.28	32.62		
00:00	528	429			97	16%			32.13	31.53		
18/06/2019									31.88	30.42		
01:00	512	447			65	13%			31.40	30.72		
18/06/2019									30.63	31.32		
02:00	508	394			113	22%			30.00	31.04		
18/06/2019									29.70	31.46		
03:00	500	418			82	16%			30.87	32.40		
18/06/2019									31.97	34.87		
04:00	491	456			35	7%			33.81	37.52		
18/06/2019									36.98	41.48		
05:00	481	447			35	7%			39.52	46.57		
18/06/2019									42.07	45.05		
06:00	488	450			38	7%			39.12	40.57		
18/06/2019									37.88	37.73		
07:00	512	462			50	10%			36.57	37.77		
18/06/2019									35.74	37.29		
08:00	518	470			48	9%			35.22	36.56		
18/06/2019									34.18	36.03		
09:00	540	477			62	12%			33.73	36.63		
18/06/2019									34.29	36.89		
10:00	587	488			121	21%			34.25	37.65		
18/06/2019									33.83	37.69		
11:00	598	492			103	17%			33.60	37.81		
18/06/2019												
12:00	584	473			111	19%						
18/06/2019												
13:00	590	470			120	20%						
18/06/2019												
14:00	610	475			135	22%						
18/06/2019												
15:00	654	614			40	6%						
18/06/2019												
16:00	655	614			41	6%						
18/06/2019												
17:00	653	568			85	13%						
18/06/2019												
18:00	636	539			97	16%						
18/06/2019												
19:00	624	523			101	16%						
18/06/2019												
20:00	632	524			108	17%						
18/06/2019												
21:00	610	511			99	16%						
18/06/2019												
22:00	521	479			42	8%						
18/06/2019												
23:00	509	475			34	7%						
Day Total	19533	11673			7860	14%						

Date	Total chiller consumption in kWh with Smart Cooling™ OFF 19 June	Total chiller consumption in kWh with Smart Cooling™ ON 5 June	Savings in kWh	Savings in %	Chiller load with Smart Cooling™ OFF	Chiller load with Smart Cooling™ ON	Temperature with Smart Cooling™ OFF 19 June	Temperature with Smart Cooling™ ON 5 June
19/06/2019 00:00	561	428	133	24%	85%	85%	33.88	37.42
19/06/2019 01:00	588	425	161	27%			34.43	38.78
19/06/2019 02:00	558	427	131	24%			34.89	38.12
19/06/2019 03:00	528	434	95	18%			34.52	35.29
19/06/2019 04:00	510	468	42	8%			34.24	34.85
19/06/2019 05:00	500	448	54	11%			33.93	34.53
19/06/2019 06:00	500	448	52	10%			33.65	34.81
19/06/2019 07:00	519	457	62	12%			33.84	35.66
19/06/2019 08:00	575	472	104	18%			34.27	38.73
19/06/2019 09:00	558	474	83	15%			35.35	38.78
19/06/2019 10:00	577	467	110	19%			37.23	41.86
19/06/2019 11:00	597	482	115	19%			41.03	46.33
19/06/2019 12:00	635	388	247	39%			42.98	46.50
19/06/2019 13:00	644	414	230	36%			40.22	40.30
19/06/2019 14:00	621	429	193	31%			37.99	39.16
19/06/2019 15:00	634	560	74	12%			36.52	37.80
19/06/2019 16:00	635	528	107	17%			36.46	36.60
19/06/2019 17:00	637	525	112	18%			34.55	36.06
19/06/2019 18:00	638	531	108	17%			33.70	35.35
19/06/2019 19:00	589	517	72	12%			32.99	34.74
19/06/2019 20:00	578	451	128	22%			32.92	34.96
19/06/2019 21:00	571	383	189	33%			32.89	35.40
19/06/2019 22:00	524	377	148	28%			32.51	35.89
19/06/2019 23:00	493	405	89	18%			32.25	35.43
Total of day	13769	10933	2836	21%				

Date	Total chiller consumption in kWh with Smart Cooling™ OFF	Total chiller consumption in kWh with Smart Cooling™ ON	Savings in kWh	Savings in %	Chiller load with Smart Cooling™ OFF	Chiller load with Smart Cooling™ ON	Temperature with Smart Cooling™ OFF	Temperature with Smart Cooling™ ON
	20 June	6 June					20 June	6 June
20/06/2019			88%	29%	79%	88%	32.44	35.13
00:00	537	377						
20/06/2019								
01:00	527	353						
20/06/2019								
02:00	516	347						
20/06/2019								
03:00	504	337						
20/06/2019								
04:00	490	424						
20/06/2019								
05:00	495	400						
20/06/2019								
06:00	497	399						
20/06/2019								
07:00	488	411						
20/06/2019								
08:00	530	451						
20/06/2019								
09:00	613	516						
20/06/2019								
10:00	613	508						
20/06/2019								
11:00	647	507						
20/06/2019								
12:00	712	509						
20/06/2019								
13:00	731	512						
20/06/2019								
14:00	709	501						
20/06/2019								
15:00	693	566						
20/06/2019								
16:00	690	568						
20/06/2019								
17:00	685	554						
20/06/2019								
18:00	674	527						
20/06/2019								
19:00	691	510						
20/06/2019								
20:00	733	517						
20/06/2019								
21:00	728	475						
20/06/2019								
22:00	625	423						
20/06/2019								
23:00	580	410						
Day Total	14707	11091						

Date	Total chiller consumption in kWh with Smart Cooling™ OFF 21 June	Total chiller consumption in kWh with Smart Cooling™ ON 7 June	Savings in kWh	Savings in %	Chiller load with Smart Cooling™ OFF	Chiller load with Smart Cooling™ ON	Temperature with Smart Cooling™ OFF 21 June	Temperature with Smart Cooling™ ON 7 June
21/06/2019 00:00	658	433	224	34%	74%	66%	33.22	33.76
21/06/2019 01:00	609	400	209	34%			33.27	33.29
21/06/2019 02:00	607	405	201	33%			33.36	32.99
21/06/2019 03:00	602	361	251	42%			32.96	32.49
21/06/2019 04:00	670	424	245	37%			33.03	32.77
21/06/2019 05:00	599	380	218	38%			33.61	32.12
21/06/2019 06:00	588	391	178	31%			33.76	31.66
21/06/2019 07:00	578	378	200	35%			34.51	33.10
21/06/2019 08:00	601	449	162	25%			35.73	35.08
21/06/2019 09:00	628	482	135	22%			37.63	38.14
21/06/2019 10:00	729	423	307	42%			40.30	39.04
21/06/2019 11:00	722	464	258	38%			41.61	41.30
21/06/2019 12:00	783	467	316	40%			41.84	41.62
21/06/2019 13:00	780	459	321	41%			38.43	38.99
21/06/2019 14:00	788	494	275	38%			38.87	38.35
21/06/2019 15:00	716	482	233	33%			35.55	36.68
21/06/2019 16:00	758	475	283	37%			34.96	35.90
21/06/2019 17:00	626	490	136	22%			34.57	35.29
21/06/2019 18:00	632	444	188	32%			34.27	34.26
21/06/2019 19:00	635	432	203	32%			34.02	34.30
21/06/2019 20:00	730	428	304	42%			34.05	35.04
21/06/2019 21:00	620	419	201	32%			33.96	35.29
21/06/2019 22:00	502	347	155	31%			33.81	35.01
21/06/2019 23:00	499	354	145	29%			33.69	34.69
Day Total	15619	10280	5339	34%				
PERIOD TOTAL	70112	53386	16726	24%				

## Test 2: 30-day Summary

Test No.2 was carried out for the period of 30 days, between 31 May and 30 June 2019. During this period, the chillers' electricity consumption was calculated with *Smart Cooling*™ turned ON.

The **Carrier 30XA 1002** chillers operated with the *Smart Cooling*™ unit **ON** for consecutive 20 days, during when the total energy consumption of the chillers' MW/h was measured.

### Measured consumption with *Smart Cooling*™ **ON**

*Smart Cooling*™ equipment was **ON** for 20 days with an average hotel occupancy of **72%**. In 20 days, total chiller consumption was of **221.41 MW/h**, an average of **11.07 MW/h** per day.

- **Formula:**  $(221.41 \text{ MW/h} \div 20 \text{ days}) = 11.07 \text{ MW/h}$  on a 24-hour average.


### Measured consumption with *Smart Cooling*™ **ON**

*Smart Cooling*™ equipment was **OFF** for 9 days with an average hotel occupancy of **82%**. In 9 days, total chiller consumption was of **129.06 MW/h**, an average of **14.34 MW/h** per day.

- **Formula:**  $(129.06 \text{ MW/h} \div 9 \text{ days}) = 14.34 \text{ MW/h}$  on a 24-hour average.

### Test Nr. 2 summary:

After a 30-day, 24-hour comparison test of average electricity consumption of a **Carrier 30XA1002**, we ascertained that average savings were of **2 to 3 MM/h**, contingent on the hotel's occupancy rate. Total 30-day water consumption, including *Smart Cooling*™ maintenance was **375 m³**.



## Test 2

30-day overview with Smart Cooling™ turned **ON** and **OFF**

Smart Cooling™ Water and Electricity Consumption Readings								
Date	Previous water consumption in m³	Current water consumption in m³	Total Consumed	Total MWh consumed	OCCP %	Smart Cooling™ operational notes	Average ambient air temperature	Highest ambient air temperature
31/05/2019	0	36	7918.56	8.77	47.06	On - final adjustments performed	34	43
01/06/2019	36	50	3079.44	8.25	47.06	on	34	40
02/06/2019	50	60	2199.6	8.43	47.06	on	34	43
03/06/2019	60	78	3959.28	9.41	54.04	on	33	39
04/06/2019	78	95	3739.32	11.67	57.94	on	36	46
05/06/2019	95	112	3739.32	10.83	76.32	on	37	46
06/06/2019	112	130	3959.28	11.09	83.29	on	37	47
07/06/2019	130	148	3959.28	10.28	77.44	on	35	41
08/06/2019	148	162	3079.44	9.92	68.02	on	35	45
09/06/2019	162	175	2859.48	10.43	77.16	on	35	43
10/06/2019	175	184	1979.64	11.36	81.82	on - after 14:00, one Smart Cooling™ circuit not operating	33	41
11/06/2019	184	197	2859.48	12.2	82.73	on - after 14:00, one Smart Cooling™ circuit not operating	35	42
12/06/2019	197	212	3299.4	12.27	86.07	on	37	44
13/06/2019	212	228	3519.56	12.13	93.31	on	37	44
14/06/2019	228	241	2859.48	12.46	88.86	on	36	44
15/06/2019	241	254	2859.48	12.54	77.16	on	35	43
16/06/2019	254	265	2419.56	12.54	88.35	on	35	42
17/06/2019	265	274	1979.64	12.48	84.96	At 17:00, Smart Cooling™ turned off	34	43
18/06/2019	274	274	0	13.53	88.35	off	34	43
19/06/2019	274	274	0	13.77	85.24	off	35	43
20/06/2019	274	274	0	14.71	88.02	off	35	45
21/06/2019	274	274	0	15.62	74.37	off	35	42
22/06/2019	274	285	2419.56	16.01	74.09	Off (cleaning process)	37	44
23/06/2019	285	294	1979.64	15.36	78.55	Off (cleaning process)	37	43
24/06/2019	294	294	0	13.58	83.84	off	36	44
25/06/2019	294	294	0	12.06	83.29	off	35	43
26/06/2019	294	294	0	13.52	88.91	off	37	42
27/06/2019	294	309	3299.4	12.82	85.79	On, after 15:00	37	44
28/06/2019	309	332	5059.08	12.68	79.67	on	37	44
29/06/2019	332	355	5059.08	12.03	71.03	on	36	43
30/06/2019	355	375	4399.2	11.83	76.32	on	37	47

## ROI Summary:

### Calculated savings:

- Daily electricity savings = 2.5 Mw/h X 0.45 AED (energy supply rate) = **AED 1,125**.
- Monthly electricity savings = AED 1,125 X 30 days = **AED 33,750**.

### Operation costs:

- Monthly water consumption = 375 m3 X 10 AED (water supply rate) = **AED 3,750**.
- Biochemical materials and maintenance costs = **AED 600**.
- Total operational costs = **AED 4,350**.
- Monthly net savings = AED 33,750 - AED 4,350 = **AED 29,400**.

### Equipment costs:

- 2 Smart Cooling™ devices = **AED 210,000 (Inc. VAT)**

### Return on Investment (ROI):

- 2 Smart Cooling™ devices =  $210,000 / (29,400 \times 8) = \mathbf{10.7 \text{ Months}}$

#### ROI Calculation Notes:

*There are effectively eight operating months comprising heat season and four months with negligible savings, which were not considered for the purposes of this ROI calculation.*

As per the readings above, measured savings range from **2 to 3 MW/h** per day. For estimation purposes, we have based the ROI calculation on average savings of **2.5 MW/h**.

ROI calculation is contingent on a building's cooling requirements and external air temperature).

Luca Gallarate  
31 July 2019



## Annex:



Riels instruments srl  
Viale Spagna, 16  
35020 Ponte San Nicolò (PD) - ITALY  
Ph. +39 0498961771 | info@riels.it



## RIF600 | Clamp-on Ultrasonic Meter Calibration Report

Pipe diameter	DN80	Date	15/12/2018
Ambient temperature	29°C		
Standard Device before test	Normal	Model	RIF600W
Standard Devide After Test	Normal		
Test result	Qualified		
Measured Medium	Water		
Accuracy	1%		
Signal Strength	UP: 90 DOWN: 90		
Standard device name	Static volumetric method/standard Meter Method Water Flow/Standard Device		
Standard device accuracy	0,20%		

Test	Standard Meter flow		Temperature	Pressure	Tested Meter Flow		Basic Error	Repeatability
	m3/h	°C			m3/h	%		
Point	101,52	101,47	25,0	0,300	102,27	102,10	0,739	-0,147
	101,47		25,0	0,300	102,07			
	101,42		25,0	0,300	101,97			
Point 1	71,27	71,27	25,0	0,300	71,75	71,75	0,673	0,147
	71,19		25,0	0,300	71,65			
	71,34		25,0	0,300	71,86			
Point 2	26,32	26,36	25,0	0,300	26,51	26,55	0,722	-0,146
	26,36		25,0	0,300	26,56			
	26,39		25,0	0,300	26,58			
Point 3	26,36	26,36	25,0	0,300	26,56	26,55	0,759	-0,132
	26,39		25,0	0,300	26,58			
	26,32		25,0	0,300	26,51			

Verification Based on JJG 1030-2007 < Ultrasonic flowmeter verification procedures >  
Scale Factor=1





Riels instruments srl  
Viale Spagna, 16  
35020 Ponte San Nicolò (PD) - ITALY  
Ph. +39 0498961771 | info@riels.it



## RIF600 |Test Report misuratore di portata ad ultrasuoni clamp on

Diametro tubazione	DN80	Date	15/12/2018
Temperatura ambiente	29°C		
Dispositivo standard prima del test	Normale	Model:	RIF600W
Dispositivo standard dopo il test	Normale		
Resultato del test	Qualified		
Liquido	Acqua		
Accuratezza	1%		
Potenza dei segnali	UP: 90 DOWN: 90		
Tipo di dispositivo standard	Metodo volumetrico statico/Misuratore di portata volumetrico		
Accuratezza del dispositivo standa	0,20%		

Test	Misuratore standard		Temperatura	Pressione	Misuratore testato		errore base	Ripetibilità
	Punti	m3/h			°C	Mpa	m3/h	
Punto 1	101,52		25,0	0,300	102,27		0,739	-0,147
	101,47	101,47	25,0	0,300	102,07	102,10	0,591	
	101,42		25,0	0,300	101,97		0,542	
Punto 2	71,27		25,0	0,300	71,75		0,673	0,147
	71,19	71,27	25,0	0,300	71,65	71,75	0,646	
	71,34		25,0	0,300	71,86		0,729	
Punto 3	26,32		25,0	0,300	26,51		0,722	-0,132
	26,36	26,36	25,0	0,300	26,56	26,55	0,759	
	26,39		25,0	0,300	26,58		0,720	

Verification Based on JJG 1030-2007 < Ultrasonic flowmeter verification procedures >  
Scale Factor=1

